



Cal/OSHA, DOT HAZMAT, EEOC, EPA, HAZWOPER, HIPAA, IATA, IMDG, TDG, MSHA, OSHA, and Canada OHS Regulations and Safety Online Training

Since 2008

**This document is provided as a training aid
and may not reflect current laws and regulations.**

Be sure and consult with the appropriate governing agencies
or publication providers listed in the "Resources" section of our website.

www.ComplianceTrainingOnline.com



[Facebook](#)



[LinkedIn](#)



[Twitter](#)



[Website](#)



Can-Technologies Inc.
An Engineering Company

Safety Solutions

“Electrical Arc Flash Hazards & What it Means to You”

**CANEW 2011 - Montreal
22nd September 2011**





Electrical Arc Flash Safety



Agenda

Hazards of Arc Flash

- What is an Arc Flash, What are the Causes, What are the Potential Hazards , Where do they Occur and What are the Impacts?
- Why is an Arc Flash Analysis Needed?
- What is the Law and Who does it Effect?

Existing Codes and the New CSA Standard (CSA-Z462)

- What are your Responsibilities

Arc Flash Protection – The Process to Compliance

- Arc Flash Hazard Analysis and Report (Step Process and Detail)
- Personal Protective Equipment (PPE)
- Other Elements - Training, Mitigating Issues, etc


What is an Arc Flash?

“. . . a dangerous condition associated with the release of energy caused by an electric arc.”



What is an Electric Arc?

An electric arc is a short circuit current passing through the air





Electrical Arc Flash Safety



What is an Arc Flash?



Electrical Arc Flash Safety

What are the Causes of Electric Arcs?

Arcs can be initiated by:

- Glow to Arc Discharge
 - Dust and Impurities
 - Corrosion
 - Condensation of Vapour and Water
- Spark Discharge
 - Accidental Touching
 - Dropping or Leaving Tools/Parts
 - Rodents and other Animals
- Over Voltages across Narrow Gaps
- Equipment/Insulating Material Failure
- Improper Work Procedures



What are the Potential Hazards?

PRIMARY – Heat and Light

- Intense UV Light – Blindness
- Intense Heat – Severe Burns
 - *Superheated Ball of Gas >20,000 Deg C*
- Intense Heat – Severe Lung Damage
 - *Inhalation of Extremely Hot Air, Molten Metal, Vapourized Metal and Toxic Fumes*

Staged Arc Flash Event



Worker nearing an open electrical panel

Bright, intense flash from the arc engulfs the worker



Non-FR work clothing burns after arc exposure

What are the Potential Hazards?

SECONDARY - Pressure, Auditory and Projectile

- Intense Pressure (2000lb/ft²)
 - *Throws Workers across the Room – Bruising, Broken Bones Concussion, Collapsed Lungs or other Organ Trauma*
- Intense Sound Blast (160 dB)
 - *Deafness, Memory Loss and Brain Damage*
- High Velocity Projectiles (700mph)(Molten Metal and Objects)
 - *Blast Shrapnel can Penetrate the Body*



Electrical Arc Flash Safety

Where do they Occur?

A hazardous arc flash can occur in any electrical device in which energy is high enough to sustain an arc.

Examples:

- Panel Boards
- Switchboards
- MCC's
- Switchgear
- Motor Starters
- Drive Cabinets
- Fused Disconnects
- Busway/Plugs



What are Risk Exposure Activities?

Examples of activities which involve Arc Flash Risks:

- Racking in and out of draw-out circuit breakers
- Removing or installing circuit breakers or fuses
- Applying Safety Grounds
- Removing Panel Covers for Inspections or other activities
- Low Voltage Testing and Diagnostics





Electrical Arc Flash Safety




What are the Impacts of an Arc Flash Incident?

Treatment can require years of skin grafting and lengthy rehabilitation. The victim may never return to work or retain the same quality of life.

The above is simply not quantifiable but other direct costs are:

- Intense Treatment Costs
- Litigation Fees, Fines and Imprisonment
 - Company/Corporate/Personal
- Asset Replacement Cost
- Production Loss
- Insurance Fees





Electrical Arc Flash Safety



What are the Chances of it Happening?

- In North America (Canada/USA)
 - 5-10 Arc Flash incidents occur each day that require hospitalization
 - 1-2 Deaths occur each day from electrical events (Shock, Flash and Blast)
 - More than 2,000 workers are treated in burn centres per year with severe arc flash injuries (This does not include injuries in hospitals and clinics which go unreported)






Electrical Arc Flash Safety



What is the 'Law' and Who does it Effect?

- Arc Flash Analysis legislatively addressed Provincially and Federally
- Any and all Workers exposed to energized equipment must be trained and equipped to be protected against Arc Flash Hazards.
- An Arc Flash Analysis must be conducted on Applicable Power Distribution equipment to determine PPE.
- Arc Flash Hazards affects all Workers, Supervisors, Managers and Owners.
- The CSA Z462-08 and NFPA 70E-2009 are now harmonized and in effect.
- MOL expect Full Arc Flash Compliance.



MINISTRY OF LABOUR



Review of Codes & Standards



Existing Codes


Occupational Health & Safety Act
- Applicable regulations



US National Fire Protection Association
- Standard NFPA 70E




Canadian Standards Association
- Standard Z462



Institute of Electrical & Electronics Engineers
- Standard 1584



Canadian Electrical Code
- Rule 2-306



What is the Ontario Occupational Health & Safety Act?

“General Principles of Health and Safety in the Workplace”

OHSA

- Section 25.(2)

- Duties of an Employer
 - (a) Provide information, instruction and supervision to a worker to protect the health or safety of the worker;
 - (h) Take every precaution reasonable in the circumstances for the protection of the worker.

Known as the ***“Due Diligence Clause”***

- Similar statements for the Duties of a Constructor article 23 and Duties of a Supervisor article 27





Review of Codes & Standards



What is NFPA 70E?

National Fire Protection Association
-Standard NFPA 70E

“..... Standard for Electrical Safety in the Workplace”

“Specify requirements for a practical safe working area for workers relative to hazards arising from the use of electricity”

- 8th Edition released September 2008
- Was De Facto Standard and adopted by Canadian Companies

Should be used in conjunction with other Codes and Standards i.e. Canadian Electrical Code C22.1/2/3





Review of Codes & Standards



What is CSA Standard Z462?

Canadian Standards Association
- Standard Z462-08




“..... *Standard for Electrical Safety in Canadian Workplaces*”

“Specify requirements for a practical safe working area for workers relative to hazards arising from the use of electricity”

- “Harmonized” with NFPA 70E-2009 edition
- Released 28th December 2008

Should be used in conjunction with other Codes and Standards i.e. Canadian Electrical Code C22.1/2/3






Review of Codes & Standards



What are the elements of the CSA/NFPA Standard?

- Electrical Safety Program
 - Qualified Worker
 - Establishment of Electrically Safe Working Conditions (Lock Out Tag Out)
 - Hazard/Risk Evaluation Procedures
 - Job Briefing and Planning
 - Energized Electrical Work Permits
- Arc Flash Study & Analysis
 - Incident Energy Levels
 - Limits of Approach and Flash Protection Boundaries
 - Personal Protective Equipment (PPE)
 - Hazard Risk Categories
 - Hazard Analysis
 - Labels
 - Training





Review of Codes & Standards



What is IEEE Standard 1584?

Institute of Electrical &
Electronics Engineers
-Standard 1584



“A guide for performing Arc Flash Hazard Calculations”



Review of Codes & Standards




What is CEC Rule 2-306?

Canadian Electrical Code
- Rule 2-306



“A requirement for field-marking electrical equipment to warn persons of potential electric shock and arc flash hazards ”





Arc Flash Protection – “The Nuts and Bolts”



What are the Operating Companies Responsibilities under the New Codes?

1. Implement Qualified and General Worker Training
2. Provide Necessary Personal Protective Equipment (PPE)
3. Conduct an Arc Flash Analysis of the Power System
4. Establish Shock and Flash Protection Boundaries along with Incident Energy Levels at Working Distances
5. Affix the Appropriate Warning Labels on Equipment

Methodology (Process)





Arc Flash Protection – “The Nuts and Bolts”



What are the Steps to Compliance – Step 1




- Obtain Asset Data (Number and Type)

Asset Survey – Arc Flash
Disconnects Fused/Non Fused


Customer Name					
Location of Facility					
Asset Location					
Upstream Asset Number					
Upstream Asset Description					
Manufacturer					
Manufacturer Part Number					
Non Fused Device					
Voltage	240/120	480/277Y	208Y/120	480	600
Maximum Current	A				
Winding/Rating					
Up Type	Cu / Al				
Phase and Wires	1Ph 3W	3Ph 3W	3Ph 4W		
Line Length/Wire Size	0.00m				
Wire Conductor Type	Cu / Al				
Fused Device					
Voltage	240/120	480/277Y	208Y/120	480	600
Maximum Current	A				
Winding/Rating					
Up Type	Cu / Al				
Phase and Wires	1Ph 3W	3Ph 3W	3Ph 4W		
Line Length/Wire Size	0.00m				
Wire Conductor Type	Cu / Al				
Part Type	Fuse				
Part Rating	1 A				
Manufacturer(s)					
Part Number					
Interrupting Capacity					
Additional Notes:					
Prepared By:	Date of Survey:				
Internal Use Only	Unique ID #				

Asset Survey Form – Fused/Non-Fused Document V1.0

Tag Name	Asset Type or Description over Simple Line Diagram	Manufacturer	Type / Model	Style / Class	Connection	Prim. Voltage (kV)	Sec. Voltage (kV)	Size / Rating (kVA)	Temp. (%)	Impedance (%)
TK-01EX	General/Line Transformer	HAMMOND	ANR	DRY / K		0.48	0.277	3500	65	5
TK-PP-C3	Transformer for PP-C1	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-C2	Transformer for PP-C2	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B3	Transformer for PP-B3	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B2	Transformer for PP-B2	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B3	Transformer for PP-B3	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B4	Transformer for PP-B4	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B5	Transformer for PP-B5	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B8	Transformer for PP-B8	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B7	Transformer for PP-B7	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B8	Transformer for PP-B8	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B9	Transformer for PP-B9	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B10	Transformer for PP-B10	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-B11	Transformer for PP-B11	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-C	Transformer for PP-C	HAMMOND	AA	DRY / K		0.48	0.308/0.312	30	170	6
TK-PP-D	Transformer for PP-D	HAMMOND	AA	DRY / K		0.48	0.308/0.312	30	170	6
TK-PP-D1	Transformer for PP-D1	HAMMOND	AA	DRY / K		0.48	0.308/0.312	30	170	6
TK-PP-E1	Transformer for PP-E1	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5
TK-PP-E1Y1	Transformer for PP-E1Y1	HAMMOND	AA	DRY / K		0.48	0.308/0.312	45	170	5




What are the Steps to Compliance – Step 1a




- Kick-Off Meeting

- Meet & Greet Project Team Players
- Transfer Electrical Asset Data/Information
- Determine Conventions
 - Naming
 - Labels
- Generate Training Program Agenda
- Confirm Project Schedule/Milestones



Tag Name Sample	
Legend	055230CB-A4
05	Unit Number
53230	Thermal Subject Index
CB	Circuit Breaker
A	Power Distribution source
4	Breaker No.

Asset List	
1	Bus
2	MCC
3	Panel
4	Utility
5	Generator
6	Motor
7	Capacitor
8	Filter
9	2W-Xformer
10	3W-Xformer
11	Cable
12	Busway
13	CL-Reactor
14	HV Fused Switch
15	HV Switch
16	LV Switch
17	MV_LV_Breaker
18	UPS
19	ATS
20	CT
21	Protection Relay




Introduction and Course Objectives <ul style="list-style-type: none"> Electrical Power System Safety and Arc Flash Hazards <ul style="list-style-type: none"> What is the Last Thing it Does it Effect? What is an Arc Flash, What are the Causes, What are the Potential Hazards? Where do they Occur and What are the Impacts?
Electrical Safety in the Workplace Review <ul style="list-style-type: none"> Review of CSA Z462 and Related Codes <ul style="list-style-type: none"> Elements of CSA Z462 Related to Arc Flash Electrical Safety Program Establishing an Electrically Safe Working Condition Emergency Electrical Work Permits Incident Energy Levels Limits of Approach and Flash Protection Boundaries Hazard Risk Categories Personal Protective Equipment (PPE) Due Diligence
Practical Solutions to Mitigating Arc Flash Hazards <ul style="list-style-type: none"> Obligations and Process to Full Compliance Course Wrap Up

What are the Steps to Compliance – Step 1b



- Conduct Detailed Assessment of Asset Data
- Collect/Verify additional System/Equipment Data
- Determine Normal Modes of Operation
- Determine System Voltages and Equipment Classes



Tag Number	Asset Type / Description (see Single Line Diagram)	Manufacturer	Type / Model	Style / Class	Connection	Line Voltage (kV)	Set Voltage (kV)	Style / Rating (kA)	Temp. (°C)	Insulation (kV)
T-A	Transformer T-A (T1D "A")	CANTE	DRN	D / YG	27.6	0.48 / 0.277	3500	65	5	5.01
T-B	Transformer T-B (T1D "B")	CANTE	DRN	D / YG	27.6	0.48 / 0.277	3500	65	5.29	5.01
T-C	Transformer T-C (T1D "C")	CANTE	DRN	D / YG	27.6	0.48 / 0.277	3500	65	5.38	5.01
TX-PP-01	Generalized Transformers	HAMMOND	DRY / K		0.48	0.2	75	170	5	5.01
TX-PP-02	Transformer for PP-C1	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-03	Transformer for PP-C2	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-04	Transformer for PP-B1	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-05	Transformer for PP-B2	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-06	Transformer for PP-B3	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-07	Transformer for PP-B4	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-08	Transformer for PP-B5	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-09	Transformer for PP-B6	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-10	Transformer for PP-B7	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-11	Transformer for PP-B8	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-12	Transformer for PP-B9	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-13	Transformer for PP-B10	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-14	Transformer for PP-B11	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-15	Transformer for PP-C	HAMMOND	DRY / K		0.48	0.208/0.12	30	170	6	5.01
TX-PP-16	Transformer for PP-C1	HAMMOND	DRY / K		0.48	0.208/0.12	30	170	6	5.01
TX-PP-17	Transformer for PP-D	HAMMOND	DRY / K		0.48	0.208/0.12	35	170	6	5.01
TX-PP-18	Transformer for PP-D1	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-19	Transformer for PP-F1	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01
TX-PP-20	Transformer for PP-F1	HAMMOND	DRY / K		0.48	0.208/0.12	45	170	5	5.01

Asset Survey – Arc Flash Disconnects Fused/Non Fused											
Customer Name: _____ Asset Number: _____ Asset Location: _____ Upstream Asset Number: _____ Upstream Asset Description: _____ Manufacturer: _____ Manufacturer Part Number: _____											
Non Fused Device											
Voltage	<input checked="" type="checkbox"/> 240/120	<input type="checkbox"/> 480/277	<input type="checkbox"/> 208/120	<input checked="" type="checkbox"/> 480	<input type="checkbox"/> 600						
Maximum Current	<input checked="" type="checkbox"/> A										
Withstanding Rating											
Lug Type	<input checked="" type="checkbox"/> Cu <input type="checkbox"/> Al <input checked="" type="checkbox"/> 2Ph 3W <input type="checkbox"/> 3Ph 3W <input type="checkbox"/> 3Ph 4W										
Phases and Wires											
Line Load/Wire Size	<input checked="" type="checkbox"/> 0000										
Wire Type	<input checked="" type="checkbox"/> Cu <input type="checkbox"/> Al										
Fuse Type											
Fuse Rating	<input checked="" type="checkbox"/> A										
Manufacturer(s)											
Part Number											
Interrupting Capacity											
Additional Notes:											
Prepared By: _____ Date of Survey: _____ Internet Use Only: <input checked="" type="checkbox"/> Unique ID: _____											
New Survey Form – Function Fused – Dispersed 10.0											




Arc Flash Protection – “The Nuts and Bolts”



What are the Steps to Compliance – Step 2



- Generate Electrical Single Line Diagram (Standard)




What are the Steps to Compliance – Step 3a



- Conduct a Short Circuit Study

Arc Fault Bus Name	Arc Fault Bus KV	Upstream Trip Device	Equip Type	Gnd	Arc Gap (mm)	Bolted Fault (kA)
89XFO01-PRI	27.60	89-LBS-01	Open Air	X	254	15.15
89XFO02-PRI	27.60	89-LBS-02	Open Air	X	254	15.15
89XFO03-PRI	27.60	89-LBS-03	Open Air	X	254	15.46
89XFO04-PRI	27.60	89-LBS-04	Open Air	X	254	15.46
89XFO05-PRI	27.60	89-LBS-05	Open Air	X	254	15.46
NEW SWG	27.60	FS-5E	Switchgear	X	254	15.51
POLE 5E	27.60	FS-MAIN	Open Air	X	254	15.60
POLE-7E	27.60	FS-MAIN	Open Air	X	254	15.26
POLE-9	27.60	FS-MAIN	Open Air	X	254	16.49
T-S1-PRI	27.60	FS-9	Open Air	X	254	16.28
108XFM001-PRI	4.16	3-F2A	Open Air		102	8.44
430-CMP-007	4.16	3-F4	Other		102	9.03
96-SWG-03	4.16	89-LBS-03	Switchgear		102	9.18
- A -	0.60	007PDP001-13	Panel	X	25	0.25
200XFM01-PRI	0.60	S1-7	Other	X	32	45.88
AIR CONV	0.60	CMPMC-7	Panel	X	25	7.42
AIR DRYER	0.60	BLM_SPL-7	Panel	X	25	3.32

What are the Steps to Compliance – Step 3b



-Conduct an Equipment Duty Study

Equipment			Ratings		Duties		Comments	Recommendation		
ID	Manufacturer	Style	1/2 Cycle kA	1/2 Cycle kA	1/2 Cycle Percent		Type	1/2 Cycle Rated kA	1/2 Cycle Duty %	
96-MCC-01			42	58.00	38.1%	VIOLATION				
96-MCC-02			42	58.84	40.1%	VIOLATION				
96-MCC-03			42	53.69	27.8%	VIOLATION				
96-MCC-04			42	53.69	27.8%	VIOLATION				
96-MCC-05			42	40.35	-3.9%	Warning				
1-F1	Federal Pioneer	65H-3 (1600)	65	62.23	-4.3%	Warning				
1-F2	Federal Pioneer	65H-3 (1600)	65	62.23	-4.3%	Warning				
1-F6	Federal Pioneer	65H-3 (1600)	65	62.23	-4.3%	Warning				
96-SWG-01			65	62.23	-4.3%	Warning				
4-F1	Cutler Hammer	MDL	50	67.61	35.2%	VIOLATION	C-H HMDL	65	4.0%	
4-F3	Cutler Hammer	ND	50	62.57	25.1%	VIOLATION	C-H HND	65	-3.7%	
4-F2	Cutler Hammer	MDL	50	67.61	35.2%	VIOLATION	C-H HMDL	65	4.0%	
4-F5	Cutler Hammer	MDL	50	67.61	35.2%	VIOLATION	C-H HMDL	65	4.0%	
4-F6	Cutler Hammer	MDL	50	66.26	32.5%	VIOLATION	C-H HMDL	65	1.9%	
4-F4	Cutler Hammer	MDL	50	67.61	35.2%	VIOLATION	C-H HMDL	65	4.0%	
4-F7	Cutler Hammer	MDL	50	67.61	35.2%	VIOLATION	C-H HMDL	65	4.0%	
96-SWG-04			65	64.01	-1.5%	Warning				
5-F1	Cutler Hammer	MDL	50	63.59	27.2%	VIOLATION	C-H HMDL	65	-2.2%	
5-F2	Cutler Hammer	MDL	50	63.59	27.2%	VIOLATION	C-H HMDL	65	-2.2%	
5-F3	Cutler Hammer	MDL	50	61.03	22.1%	VIOLATION	C-H HMDL	65	-6.1%	
5-F4	Cutler Hammer	HKD	65	63.59	-2.2%	Warning				
5-F5	Cutler Hammer	MDL	50	63.59	27.2%	VIOLATION	C-H HMDL	65	-2.2%	
5-F7	Cutler Hammer	MDL	50	63.59	27.2%	VIOLATION	C-H HMDL	65	-2.2%	
008-PDP-001			42	40.31	-4.0%	Warning				
050-PDP-003			42	44.78	6.6%	VIOLATION				




Arc Flash Protection – “The Nuts and Bolts”




What are the Steps to Compliance – Step 3c



-Conduct a Protective Device Coordination Study



Can-Technologies	<i>EasyPower®</i> TIME-CURRENT CURVES	SW-CR-B1-02
Notes:		FAULT:
- Generic fuses used; actual fuse data not provided.		DATE: Jun 18, 2010
- Breaker 9-1 trip settings not provided; maximum settings used.		BY: Frank Kavvou
		REVISION: original



Can-Technologies	EasyPower® TIME-CURRENT CURVES	SW-CR-B1-02
Notes:		FAULT:
- Generic fuses used, actual fuse data not provided.		DATE: Jun 18, 2010
- Breaker trip settings should be tested by end-user.		BY: Frank Kavos
- Breaker 9-1 settings need to be finalized with "old" building assets.		REVISION: co-ordinated



Arc Flash Protection – “The Nuts and Bolts”



What are the Steps to Compliance – Step 3d



- Calculate Thermal Incident Energy Exposure Values
- Determine Hazard Risk Categories

Incident Energy From (cal/cm ²)	Incident Energy To (cal/cm ²)	Hazard Risk Category
0.0	1.2	0
1.2	4.0	1
4.0	8.0	2
8.0	25.0	3
25.0	40.0	4

Arc Fault Bus Name	Arc Fault Bus kV	Upstream Trip Device Name	Equip Type	Gnd	Arc Gap (mm)	Bolted Fault (kA)	Est Arc Fault (kA)	Trip Time (sec)	Opening Time (sec)	Arc Time (sec)	Est Arc Flash Boundary (inches)	Working Distance (inches)	Incident Energy (cal/cm ²)	Required Clothing Class
89XFO01-PRI	27.6	89-LBS-01	Open Air	X	254	15.15	15.15	0.022	0	0.022	69.8	31	7.6	#2
89XFO02-PRI	27.6	89-LBS-02	Open Air	X	254	15.15	15.15	0.022	0	0.022	69.8	31	7.6	#2
89XFO03-PRI	27.6	89-LBS-03	Open Air	X	254	15.46	15.46	0.025	0	0.025	74.8	31	8.7	#3
89XFO04-PRI	27.6	89-LBS-04	Open Air	X	254	15.46	15.46	0.025	0	0.025	74.8	31	8.7	#3
89XFO05-PRI	27.6	89-LBS-05	Open Air	X	254	15.46	15.46	0.025	0	0.025	74.8	31	8.7	#3
NEW SWG	27.6	FS-5E	Switchgear	X	254	15.514	15.514	0.029	0	0.029	81.2	31	10.3	#3
POLE 5E	27.6	FS-MAIN	Open Air	X	254	15.595	15.595	0.034	0	0.034	88.5	31	12.2	#3
POLE-7E	27.6	FS-MAIN	Open Air	X	254	15.26	15.26	0.034	0	0.034	87.5	31	12	#3
POLE-9	27.6	FS-MAIN	Open Air	X	254	16.485	16.485	0.034	0	0.034	90.3	31	12.7	#3
T-S1-PRI	27.6	FS-9	Open Air	X	254	16.283	16.283	0.021	0	0.021	71.1	31	7.9	#2
108XFM001-PRI	4.16	3-F2A	Open Air		102	8.44	8.22	0.038	0	0.038	12.2	26	0.3	#0
430-CMP-007	4.16	3-F4	Other		102	9.03	8.78	0.01	0	0.01	3	18	0.3	#0
96-SWG-03	4.16	89-LBS-03	Switchgear		102	9.18	8.92	0.182	0	0.182	72.1	18	4.6	#2
- A -	0.6	007PDP001-13	Panel	X	25	0.25	*0.223	3.203	0	3.203	22.6	18	1.7	#1
200XFM01-PRI	0.6	S1-7	Other	X	32	45.88	*25.271	0.017	0	0.017	19.3	18	1.7	#1
AIR CONV	0.6	CMPMC-7	Panel	X	25	7.42	5.97	0.012	0	0.012	5.6	18	0.2	#0
AIR DRYER	0.6	BLM_SPL-7	Panel	X	25	3.32	2.85	0.012	0	0.012	3.4	18	0.1	#0
ATLASCOPCO 1	0.6	CMPMC-10	Panel	X	25	12.95	9.97	0.012	0	0.012	7.8	18	0.4	#0
ATLASCOPCO 2	0.6	CMPMC-3	Panel	X	25	12.95	9.97	0.012	0	0.012	7.8	18	0.4	#0
BLM SPLITTER	0.6	S2-2	Other	X	32	15.491	*9.512	0.03	0	0.03	13.5	18	1	#0
BLM VENT	0.6	BLM_SPL-5	Panel	X	25	3.23	*2.359	0.022	0	0.022	4.6	18	0.2	#0
CMP 1	0.6	BLM_SPL-10	Panel	X	25	13.229	*8.645	0.037	0	0.037	15	18	1.1	#0
CMP. MCC	0.6	S2-1	MCC	X	25	24.911	*15.488	0.028	0	0.028	19	18	1.6	#1
COMP FAN	0.6	BLM_SPL-6	Panel	X	25	3.322	2.847	0.012	0	0.012	3.4	18	0.1	#0
CONVEYOR	0.6	BLM_SPL-9	Panel	X	25	3.374	2.888	0.012	0	0.012	3.5	18	0.1	#0
COOL.TWR	0.6	BLM_SPL-8	Panel	X	25	3.374	2.888	0.012	0	0.012	3.5	18	0.1	#0
DOOR 20	0.6	BLM_SPL-1	Panel	X	25	3.297	2.828	0.012	0	0.012	3.4	18	0.1	#0
DOOR 21	0.6	BLM_SPL-4	Panel	X	25	3.297	2.828	0.012	0	0.012	3.4	18	0.1	#0

What is Thermal Incident Arc Flash Energy?

Thermal Incident Energy is measured in Calories/cm² (1.2 Calories/cm² is the threshold of a second degree burn)

Arc Flash protection is to limit the injury to no more than the “just curable” 2nd Degree Burn.

Personal Protective Equipment (PPE) is selected based on this Calculated Value




1.2 Calories/cm² =
Holding your finger in
the blue part of the
flame for one second

What are the Steps to Compliance – Step 3e




- Calculate Flash Protection Approach Boundary
- Calculate Shock Protection Approach Boundaries



Arc Fault Bus Name	Arc Fault Bus kV	Upstream Trip Device Name	Equip Type	Gnd	Arc Gap (mm)	Bolted Fault (kA)	Est Arc Fault (kA)	Trip Time (sec)	Opening Time (sec)	Arc Time (sec)	Est Arc Flash Boundary (inches)	Working Distance (inches)	Incident Energy (cal/cm ²)	Required Clothing Class
89XFO01-PRI	27.6	89-LBS-01	Open Air	X	254	15.15	15.15	0.022	0	0.022	69.8	31	7.6	#2
89XFO02-PRI	27.6	89-LBS-02	Open Air	X	254	15.15	15.15	0.022	0	0.022	69.8	31	7.6	#2
89XFO03-PRI	27.6	89-LBS-03	Open Air	X	254	15.46	15.46	0.025	0	0.025	74.8	31	8.7	#3
89XFO04-PRI	27.6	89-LBS-04	Open Air	X	254	15.46	15.46	0.025	0	0.025	74.8	31	8.7	#3
89XFO05-PRI	27.6	89-LBS-05	Open Air	X	254	15.46	15.46	0.025	0	0.025	74.8	31	8.7	#3
NEW SWG	27.6	FS-5E	Switchgear	X	254	15.514	15.514	0.029	0	0.029	81.2	31	10.3	#3
POLE 5E	27.6	FS-MAIN	Open Air	X	254	15.595	15.595	0.034	0	0.034	88.5	31	12.2	#3
POLE-7E	27.6	FS-MAIN	Open Air	X	254	15.26	15.26	0.034	0	0.034	87.5	31	12	#3
POLE-9	27.6	FS-MAIN	Open Air	X	254	16.485	16.485	0.034	0	0.034	90.3	31	12.7	#3
T-S1-PRI	27.6	FS-9	Open Air	X	254	16.283	16.283	0.021	0	0.021	71.1	31	7.9	#2
108XFM001-PRI	4.16	3-F2A	Open Air		102	8.44	8.22	0.038	0	0.038	12.2	26	0.3	#0
430-CMP-007	4.16	3-F4	Other		102	9.03	8.78	0.01	0	0.01	3	18	0.3	#0
96-SWG-03	4.16	89-LBS-03	Switchgear		102	9.18	8.92	0.182	0	0.182	72.1	18	4.6	#2
- A -	0.6	007PDP001-13	Panel	X	25	0.25	*0.223	3.203	0	3.203	22.6	18	1.7	#1
200XFM01-PRI	0.6	S1-7	Other	X	32	45.88	*25.271	0.017	0	0.017	19.3	18	1.7	#1
AIR CONV	0.6	CMPMC-7	Panel	X	25	7.42	5.97	0.012	0	0.012	5.6	18	0.2	#0
AIR DRYER	0.6	BLM_SPL-7	Panel	X	25	3.32	2.85	0.012	0	0.012	3.4	18	0.1	#0
ATLASCOPCO 1	0.6	CMPMC-10	Panel	X	25	12.95	9.97	0.012	0	0.012	7.8	18	0.4	#0
ATLASCOPCO 2	0.6	CMPMC-3	Panel	X	25	12.95	9.97	0.012	0	0.012	7.8	18	0.4	#0
BLM SPLITTER	0.6	S2-2	Other	X	32	15.491	*9.512	0.03	0	0.03	13.5	18	1	#0
BLM VENT	0.6	BLM_SPL-5	Panel	X	25	3.23	*2.359	0.022	0	0.022	4.6	18	0.2	#0
CMP 1	0.6	BLM_SPL-10	Panel	X	25	13.229	*8.645	0.037	0	0.037	15	18	1.1	#0
CMP. MCC	0.6	S2-1	MCC	X	25	24.911	*15.488	0.028	0	0.028	19	18	1.6	#1
COMP FAN	0.6	BLM_SPL-6	Panel	X	25	3.322	2.847	0.012	0	0.012	3.4	18	0.1	#0
CONVEYOR	0.6	BLM_SPL-9	Panel	X	25	3.374	2.888	0.012	0	0.012	3.5	18	0.1	#0
COOL. TWR	0.6	BLM_SPL-8	Panel	X	25	3.374	2.888	0.012	0	0.012	3.5	18	0.1	#0
DOOR 20	0.6	BLM_SPL-1	Panel	X	25	3.297	2.828	0.012	0	0.012	3.4	18	0.1	#0
DOOR 21	0.6	BLM_SPL-4	Panel	X	25	3.297	2.828	0.012	0	0.012	3.4	18	0.1	#0

What are the Shock and Arc Flash Boundaries ?









Arc Flash Protection – “The Nuts and Bolts”



What are the Steps to Compliance – Step 4a



- Generate Mitigating Analysis – Report
- Conduct Analysis Review Meeting



Suggested protective devices and/or settings are shown in table below:

AF Fault Bus Name	Existing Trip Device & Setting	Existing IE / HRC	Suggested Trip Device Setting	New IE / HRC
RP-CR-B2-02	PP-CR-B2-01 Inst = 2850A	21.4 cal/cm ² HRC #3	Inst = 2250A (middle position) or lower	0.2 cal/cm ² HRC #0

What are the Steps to Compliance – Step 4b



-Recommend Required PPE



Incident Energy From (cal/cm ²)	Incident Energy To (cal/cm ²)	Hazard Risk Category
0.0	1.2	0
1.2	4.0	1
4.0	8.0	2
8.0	25.0	3
25.0	40.0	4

PPE Category 0 < 1.2 Cal/cm²

- Non-Melting Untreated Natural Fibers
- Long Sleeve Shirt
- Long Pants
- **OR** Overalls
- Safety Glasses
- Hearing Protection
- Hard Hat
- Safety Shoes (Green Label)
- Gloves (Applicable to Voltage Class)



PPE Category 1 <4 Cal/cm²

- Fire Resistant Long Sleeve Shirt
- Fire Resistant Long Pants with Minimum arc rating of 4 Cal/cm²
- **OR** Fire Resistant Coveralls with Minimum arc rating of 4 Cal/cm² (in place of Shirt and Pants)
- Safety Glasses
- Hearing Protection
- Hard Hat and Face Shield (8 cal/cm² is standard)
- Safety Shoes (Green Label)
- Gloves (Applicable to Voltage Class)



PPE Category 2 < 8 Cal/cm²

- Fire Resistant Long Sleeve Shirt
- Fire Resistant Long Pants with minimum arc flash rating of 8 cal/cm²
- **OR** Fire Resistant Coveralls with minimum arc flash rating of 8 cal/cm² (in place of Shirt and Pants)
- Cotton Undergarments
- Safety Glasses
- Hearing Protection
- Hard Hat and Face Shield with minimum arc flash rating of 8 cal/cm²
- **AND** wrap around Sock Hood for forehead, ears, neck (Could use a flash suit hood)
- Safety Shoes (Green Label)
- Gloves (Applicable to Voltage Class)



PPE Category 3 < 25 Cal/cm²

- Fire Resistant Long Sleeve Shirt and Pants **AND** Fire Resistant Coveralls
- **OR** 2 sets of Fire Resistant Coveralls
- Flash Suit Hood
- Cotton Undergarments
- Safety Glasses
- Hearing Protection
- Safety Shoes
- Gloves (Applicable to Voltage Class)




PPE Category 4 < 40 Cal/cm²



- Fire Resistant Long Sleeve Shirt and Pants **OR** Coveralls (Cat 2)
- **AND** Flash Suit and Hood
- Cotton Undergarments
- Safety Glasses
- Hearing Protection
- Safety Shoes
- Gloves (Applicable to Voltage Class)



What are the Steps to Compliance – Step 4c



- Create Detailed Arc Flash Analysis Report
 - Asset Details & Single Line Diagrams
 - Short Circuit Study
 - Equipment Duty Study
 - Protective Device Coordination Study
 - Arc Flash Study
 - PPE Recommendations
- Create Arc Flash Labels
- Create Compliance Letter
- Training (Awareness/Detailed)
- PPE Sizing and Application





Arc Flash Protection – “The Nuts and Bolts” *Labels*



WARNING			
600V AC	Arc Flash and Shock Hazard		
1.07 meters / 42" (Shock) 30cm / 12" (Shock) 25mm / 1" (Shock) 46cm /18" (Flash) 1.24 meters / 48.8" (Flash)	Limited Approach Boundary (Qualified Persons Only/PPE Required) Restricted Approach Boundary (PPE Required) Prohibitive Approach Boundary (PPE Required) Working Distance Flash Protection Boundary (PPE Required)		
Category 2	PPE Required (6.9cal/cm²)		
Eye and Head	Safety Glasses, Electrically Rated Hard Hat, 8cal/cm ² Hood and Face Shield, Hearing Protection		
Body	Cotton Underwear, FR Resistant Shirt (Long Sleeve) and Pants (Long) OR Overalls - Min Arc Flash Rating 8cal/cm ²		
Hand and Arm	>50V = Voltage Related/Insulated Tools, Class 0 (Minimum) Gloves and Leather Outers (Flash)		
Foot	Leather Dielectric Rated Safety Shoes (Flash) or Insulating Mat (Step and Touch Potential)		
Equipment Name	MDB-B	Upstream Trip Device	ATS-1:Breaker 1
Arc Flash Analysis Conducted By	Can-Technologies Inc	Standard	IEEE 1584
Date	19 August 2011	Calculation	EasyPower V9.0.2

UV and Chemical Resistant ANSI Z535 Compliant Labels









Arc Flash Protection – “The Nuts and Bolts”



Summary of Deliverables

- Standard Electrical Single Line Diagram
- Enhanced Electrical Single Line Diagram
- Initial Study Report (Mitigating Analysis)
- Final Detailed Report
 - Asset Details
 - Short Circuit Study
 - Equipment Duty Study
 - Protective Device Coordination Study
 - Arc Flash Study
 - Recommendation of PPE
- Compliant Arc Flash Labels
- Certificate of Electrical Arc Flash Compliance
- Electrical Arc Flash Hazard Training
- Training Certificates (Individual/Summary)
- Native Format Analysis/Raw Data for Cont.




Alt Ref	Alt Ref Name	Start KM	End KM	Alt Ref Model	Grade Type	Grid	Length (km)	Relative Altitude (m)
1	BLT-1	0.0	0.0	BLT-1	Grade	Y	22.4	9.3
2	BLT-2	0.0	0.0	BLT-2	Grade	Y	22.4	9.3
3	BLT-3	0.0	0.0	BLT-3	Grade	Y	22.4	9.3
4	BLT-4	0.0	0.0	BLT-4	Grade	Y	22.4	9.3
5	BLT-5	0.0	0.0	BLT-5	Grade	Y	22.4	9.3
6	BLT-6	0.0	0.0	BLT-6	Grade	Y	22.4	9.3
7	BLT-7	0.0	0.0	BLT-7	Grade	Y	22.4	9.3
8	BLT-8	0.0	0.0	BLT-8	Grade	Y	22.4	9.3
9	BLT-9	0.0	0.0	BLT-9	Grade	Y	22.4	9.3
10	BLT-10	0.0	0.0	BLT-10	Grade	Y	22.4	9.3
11	BLT-11	0.0	0.0	BLT-11	Grade	Y	22.4	9.3
12	BLT-12	0.0	0.0	BLT-12	Grade	Y	22.4	9.3
13	BLT-13	0.0	0.0	BLT-13	Grade	Y	22.4	9.3
14	BLT-14	0.0	0.0	BLT-14	Grade	Y	22.4	9.3
15	BLT-15	0.0	0.0	BLT-15	Grade	Y	22.4	9.3
16	BLT-16	0.0	0.0	BLT-16	Grade	Y	22.4	9.3
17	BLT-17	0.0	0.0	BLT-17	Grade	Y	22.4	9.3
18	BLT-18	0.0	0.0	BLT-18	Grade	Y	22.4	9.3
19	BLT-19	0.0	0.0	BLT-19	Grade	Y	22.4	9.3
20	BLT-20	0.0	0.0	BLT-20	Grade	Y	22.4	9.3
21	BLT-21	0.0	0.0	BLT-21	Grade	Y	22.4	9.3
22	BLT-22	0.0	0.0	BLT-22	Grade	Y	22.4	9.3
23	BLT-23	0.0	0.0	BLT-23	Grade	Y	22.4	9.3
24	BLT-24	0.0	0.0	BLT-24	Grade	Y	22.4	9.3
25	BLT-25	0.0	0.0	BLT-25	Grade	Y	22.4	9.3
26	BLT-26	0.0	0.0	BLT-26	Grade	Y	22.4	9.3
27	BLT-27	0.0	0.0	BLT-27	Grade	Y	22.4	9.3
28	BLT-28	0.0	0.0	BLT-28	Grade	Y	22.4	9.3
29	BLT-29	0.0	0.0	BLT-29	Grade	Y	22.4	9.3
30	BLT-30	0.0	0.0	BLT-30	Grade	Y	22.4	9.3
31	BLT-31	0.0	0.0	BLT-31	Grade	Y	22.4	9.3
32	BLT-32	0.0	0.0	BLT-32	Grade	Y	22.4	9.3
33	BLT-33	0.0	0.0	BLT-33	Grade	Y	22.4	9.3
34	BLT-34	0.0	0.0	BLT-34	Grade	Y	22.4	9.3
35	BLT-35	0.0	0.0	BLT-35	Grade	Y	22.4	9.3
36	BLT-36	0.0	0.0	BLT-36	Grade	Y	22.4	9.3
37	BLT-37	0.0	0.0	BLT-37	Grade	Y	22.4	9.3
38	BLT-38	0.0	0.0	BLT-38	Grade	Y	22.4	9.3
39	BLT-39	0.0	0.0	BLT-39	Grade	Y	22.4	9.3
40	BLT-40	0.0	0.0	BLT-40	Grade	Y	22.4	9.3
41	BLT-41	0.0	0.0	BLT-41	Grade	Y	22.4	9.3
42	BLT-42	0.0	0.0	BLT-42	Grade	Y	22.4	9.3
43	BLT-43	0.0	0.0	BLT-43	Grade	Y	22.4	9.3
44	BLT-44	0.0	0.0	BLT-44	Grade	Y	22.4	9.3
45	BLT-45	0.0	0.0	BLT-45	Grade	Y	22.4	9.3
46	BLT-46	0.0	0.0	BLT-46	Grade	Y	22.4	9.3
47	BLT-47	0.0	0.0	BLT-47	Grade	Y	22.4	9.3
48	BLT-48	0.0	0.0	BLT-48	Grade	Y	22.4	9.3
49	BLT-49	0.0	0.0	BLT-49	Grade	Y	22.4	9.3
50	BLT-50	0.0	0.0	BLT-50	Grade	Y	22.4	9.3
51	BLT-51	0.0	0.0	BLT-51	Grade	Y	22.4	9.3
52	BLT-52	0.0	0.0	BLT-52	Grade	Y	22.4	9.3
53	BLT-53	0.0	0.0	BLT-53	Grade	Y	22.4	9.3
54	BLT-54	0.0	0.0	BLT-54	Grade	Y	22.4	9.3
55	BLT-55	0.0	0.0	BLT-55	Grade	Y	22.4	9.3
56	BLT-56	0.0	0.0	BLT-56	Grade	Y	22.4	9.3
57	BLT-57	0.0	0.0	BLT-57	Grade	Y	22.4	9.3
58	BLT-58	0.0	0.0	BLT-58	Grade	Y	22.4	9.3
59	BLT-59	0.0	0.0	BLT-59	Grade	Y	22.4	9.3
60	BLT-60	0.0	0.0	BLT-60	Grade	Y	22.4	9.3
61	BLT-61	0.0	0.0	BLT-61	Grade	Y	22.4	9.3
62	BLT-62	0.0	0.0	BLT-62	Grade	Y	22.4	9.3
63	BLT-63	0.0	0.0	BLT-63	Grade	Y	22.4	9.3
64	BLT-64	0.0	0.0	BLT-64	Grade	Y	22.4	9.3
65	BLT-65	0.0	0.0	BLT-65	Grade	Y	22.4	9.3
66	BLT-66	0.0	0.0	BLT-66	Grade	Y	22.4	9.3
67	BLT-67	0.0	0.0	BLT-67	Grade	Y	22.4	9.3
68	BLT-68	0.0	0.0	BLT-68	Grade	Y	22.4	9.3
69	BLT-69	0.0	0.0	BLT-69	Grade	Y	22.4	9.3
70	BLT-70	0.0	0.0	BLT-70	Grade	Y	22.4	9.3
71	BLT-71	0.0	0.0	BLT-71	Grade	Y	22.4	9.3
72	BLT-72	0.0	0.0	BLT-72	Grade	Y	22.4	9.3
73	BLT-73	0.0	0.0	BLT-73	Grade	Y	22.4	9.3
74	BLT-74	0.0	0.0	BLT-74	Grade	Y	22.4	9.3
75	BLT-75	0.0	0.0	BLT-75	Grade	Y	22.4	9.3
76	BLT-76	0.0	0.0	BLT-76	Grade	Y	22.4	9.3
77	BLT-77	0.0	0.0	BLT-77	Grade	Y	22.4	9.3
78	BLT-78	0.0	0.0	BLT-78	Grade	Y	22.4	9.3
79	BLT-79	0.0	0.0	BLT-79	Grade	Y	22.4	9.3
80	BLT-80	0.0	0.0	BLT-80	Grade	Y	22.4	9.3
81	BLT-81	0.0	0.0	BLT-81	Grade	Y	22.4	9.3
82	BLT-82	0.0	0.0	BLT-82	Grade	Y	22.4	9.3
83	BLT-83	0.0	0.0	BLT-83	Grade	Y	22.4	9.3
84	BLT-84	0.0	0.0	BLT-84	Grade	Y	22.4	9.3
85	BLT-85	0.0	0.0	BLT-85	Grade	Y	22.4	9.3
86	BLT-86	0.0	0.0	BLT-86	Grade	Y	22.4	9.3
87	BLT-87	0.0	0.0	BLT-87	Grade	Y	22.4	9.3
88	BLT-88	0.0	0.0	BLT-88	Grade	Y	22.4	9.3
89	BLT-89	0.0	0.0	BLT-89	Grade	Y	22.4	9.3
90	BLT-90	0.0	0.0	BLT-90	Grade	Y	22.4	9.3
91	BLT-91	0.0	0.0	BLT-91	Grade	Y	22.4	9.3
92	BLT-92	0.0	0.0	BLT-92	Grade	Y	22.4	9.3
93	BLT-93	0.0	0.0	BLT-93	Grade	Y	22.4	9.3
94	BLT-94	0.0	0.0	BLT-94	Grade	Y	22.4	9.3
95	BLT-95	0.0	0.0	BLT-95	Grade	Y	22.4	9.3
96	BLT-96	0.0	0.0	BLT-96	Grade	Y	22.4	9.3
97	BLT-97	0.0	0.0	BLT-97	Grade	Y	22.4	9.3
98	BLT-98	0.0	0.0	BLT-98	Grade	Y	22.4	9.3
99	BLT-99	0.0	0.0	BLT-99	Grade	Y	22.4	9.3
100	BLT-100	0.0	0.0	BLT-100	Grade	Y	22.4	9.3
101	BLT-101	0.0	0.0	BLT-101	Grade	Y	22.4	9.3
102	BLT-102	0.0	0.0	BLT-102	Grade	Y	22.4	9.3
103	BLT-103	0.0	0.0	BLT-103	Grade	Y	22.4	9.3
104	BLT-104	0.0	0.0	BLT-104	Grade	Y	22.4	9.3
105	BLT-105	0.0	0.0	BLT-105	Grade	Y	22.4	9.3
106	BLT-106	0.0	0.0	BLT-106	Grade	Y	22.4	9.3
107	BLT-107	0.0	0.0	BLT-107	Grade	Y	22.4	9.3
108	BLT-108	0.0	0.0	BLT-108	Grade	Y	22.4	9.3
109	BLT-109	0.0	0.0	BLT-109	Grade	Y	22.4	9.3
110	BLT-110	0.0	0.0	BLT-110	Grade	Y	22.4	9.3
111	BLT-111	0.0	0.0	BLT-111	Grade	Y	22.4	9.3
112	BLT-112	0.0	0.0	BLT-112	Grade	Y	22.4	9.3
113	BLT-113	0.0	0.0	BLT-113	Grade	Y	22.4	9.3
114	BLT-114	0.0	0.0	BLT-114	Grade	Y	22.4	9.3
115	BLT-115	0.0	0.0	BLT-115	Grade	Y	22.4	9.3
116	BLT-116	0.0	0.0	BLT-116	Grade	Y	22.4	9.3
117	BLT-117	0.0	0.0	BLT-117	Grade	Y	22.4	9.3
118	BLT-118	0.0	0.0	BLT-118	Grade	Y	22.4	9.3
119	BLT-119	0.0	0.0	BLT-119	Grade	Y	22.4	9.3
120	BLT-120	0.0	0.0	BLT-120	Grade	Y	22.4	9.3
121	BLT-121	0.0	0.0	BLT-121	Grade	Y	22.4	9.3
122	BLT-122	0.0	0.0	BLT-122	Grade	Y	22.4	9.3
123	BLT-123	0.0	0.0	BLT-123	Grade	Y	22.4	9.3
124	BLT-124	0.0	0.0	BLT-124	Grade	Y	22.4	9.3
125	BLT-125	0.0	0.0	BLT-125	Grade	Y	22.4	9.3
126	BLT-126	0.0	0.0	BLT-126	Grade	Y	22.4	9.3
127	BLT-127	0.0	0.0	BLT-127	Grade	Y	22.4	9.3
128	BLT-128	0.0	0.0	BLT-128	Grade	Y	22.4	9.3
129	BLT-129	0.0	0.0	BLT-129	Grade	Y	22.4	9.3
130	BLT-130	0.0	0.0	BLT-130	Grade	Y	22.4	9.3
131	BLT-131	0.0	0.0	BLT-131	Grade	Y	22.4	9.3
132	BLT-132	0.0	0.0	BLT-132	Grade	Y	22.4	9.3
133	BLT-133	0.0	0.0	BLT-133	Grade	Y	22.4	9.3
134	BLT-134	0.0	0.0	BLT-134	Grade	Y	22.4	9.3
135	BLT-135	0.0	0.0	BLT-135	Grade	Y	22.4	9.3
136	BLT-136	0.0	0.0	BLT-136	Grade	Y	22.4	9.3
137	BLT-137	0.0	0.0	BLT-137	Grade	Y	22.4	9.3
138	BLT-138	0.0	0.0	BLT-138	Grade	Y	22.4	9.3
139	BLT-139	0.0	0.0	BLT-139	Grade	Y	22.4	9.3
140	BLT-140	0.0	0.0	BLT-140	Grade	Y	22.4	9.3
141	BLT-141	0.0	0.0	BLT-141	Grade	Y	22.4	9.3
142	BLT-142	0.0	0.0	BLT-142	Grade	Y	22.4	9.3
143	BLT-143	0.0	0.0	BLT-143	Grade	Y	22.4	9.3
144	BLT-144	0.0	0.0	BLT-144	Grade	Y	22.4	9.3
145	BLT-145	0.0	0.0	BLT-145	Grade	Y	22.4	9.3
146	BLT-146	0.0	0.0	BLT-146	Grade	Y	22.4	9.3
147	BLT-147	0.0	0.0	BLT-147	Grade	Y	22.4	9.3
148	BLT-148	0.0	0.0	BLT-148	Grade	Y	22.4	9.3
149	BLT-149	0.0	0.0	BLT-149	Grade	Y	22.4	9.3
150	BLT-150	0.0	0.0	BLT-150	Grade	Y	22.4	9.3
151	BLT-151	0.0	0.0	BLT-151	Grade	Y	22.4	9.3
152	BLT-152	0.0	0.0	BLT-152	Grade	Y	22.4	9.3
153	BLT-153	0.0	0.0	BLT-153	Grade	Y	22.4	9.3
154	BLT-154	0.0	0.0	BLT-154	Grade	Y	22.4	9.3
155	BLT-155	0.0	0.0	BLT-155	Grade	Y	22.4	9.3
156	BLT-156	0.0	0.0	BLT-156	Grade	Y	22.4	9.3
157	BLT-157</td							



Arc Flash Protection – “The Nuts and Bolts”



Additional Measures/Requirements – Step 5



Manual Of Policies and Procedures

- **Development of Electrical Safety Program**
 - Hazard/Risk Evaluation
 - Job Briefing and Planning
 - Lock Out Tag Out Procedures*
 - Energized Electrical Work Permits
 - Maintenance/On-Site Policies and Procedures
- **On-Going Labelling Services**
- **Off-Site Data/Drawing Storage**

* Mandatory





Electrical Arc Flash Safety

PPE Category – Keep This in Mind

All of this is to answer ONE Question



What PPE do you wear in case today is a BAD DAY?

Questions?







Can-Technologies Inc.
An Engineering Company

Contact Details

Keith Gilbank – Business Development Manager
Can-Technologies Inc
1400 Bishop Street N, Suite 202
Cambridge, ON, N1R 6W8
Tel: (519) 624-9166

www.can-technologies.com

